



COUNTY OF ORANGE

HEALTH CARE AGENCY/ENVIRONMENTAL HEALTH

OCEAN AND BAY WATER CLOSURES 2019

	Sewage Spill Number	Date Closed	Date Opened	Number of Days Closed	Beach Mile Days	Ocean, Bay, Harbor Area Closed	Agency/Reason	Amount Spilled*	Storm Caused Spill
1	19-001	1/4/19	1/6/19	2	1.22	Bayside Dr. Beach to China Cove	City of Newport Beach / line blockage due to roots and grease	~425 gallons/sewage ~50 gallons recovered ~375 gallons released	N
2	19-003	1/9/19	1/12/19	3	0.282	250 feet upcoast to 250 feet downcoast from the projection of Upland Road	City of Laguna Beach / main line blockage due to roots	~600 gallons/sewage ~300 gallons recovered ~300 gallons released	N
3	19-032	3/20/19	3/23/19	3	1.83	Bayside Dr. Beach to China Cove	City of Newport Beach / Grease interceptor overflow	~150 gallons/sewage ~50 gallons recovered ~100 gallons released	N

* Amount Spilled: amount spilled - amount recovered = release amount

~ All volumes are estimations based on responding sanitation district/city field staff observations and calculations. Closures based on initial estimated amount reported by sanitation district/city field staff. Final spill volumes (in parentheses and italicized if different from original reported volumes) are reported to the Regional Water Quality Control Boards by the sanitation district/city.

PPO = Private Property Owner
 perty Owner