



## COUNTY OF ORANGE

# HEALTH CARE AGENCY/ENVIRONMENTAL HEALTH OCEAN AND BAY WATER CLOSURES 2019

|   | Sewage Spill Number | Date Closed | Date Opened | Number of Days Closed | Beach Mile Days | Ocean, Bay, Harbor Area Closed  | Agency/Reason   | Amount Spilled*  | Storm Caused Spill |
|---|---------------------|-------------|-------------|-----------------------|-----------------|---|---|--|--------------------|
| 1 | 19-001              | 1/4/19      | 1/6/19      | 2                     | 1.22            | Bayside Dr. Beach to China Cove   | City of Newport Beach / line blockage due to roots and grease | ~425 gallons/sewage<br>~50 gallons recovered<br>~375 gallons released    | N                  |
| 2 | 19-003              | 1/9/19      | 1/12/19     | 3                     | 0.282           | 250 feet upcoast to 250 feet downcoast from the projection of Upland Road                               | City of Laguna Beach / main line blockage due to roots        | ~600 gallons/sewage<br>~300 gallons recovered<br>~300 gallons released   | N                  |
| 3 | 19-032              | 3/20/19     | 3/23/19     | 3                     | 1.83            | Bayside Dr. Beach to China Cove   | City of Newport Beach / Grease interceptor overflow           | ~150 gallons/sewage<br>~50 gallons recovered<br>~100 gallons released    | N                  |
| 4 | 19-078              | 8/29/19     | 8/30/19     | 1                     | 4.51            | Anaheim Bay, Sunset Aquatic Marina, Portofino Cove, Anderson St. Marina, Mother's Beach & Admiralty Dr. | City of Stanton Public Works / Sewer main blockage            | ~60,000 gallons/sewage<br><i>(~60,000 recovered)</i><br>~60,000 released | N                  |
| 5 | 19-093              | 9/26/19     | 9/27/19     | 1                     | 0.11            | North Star Beach  | City of Newport Beach / Sewer main blockage                   | ~750 gallons/sewage<br>~250 gallons recovered<br>~500 gallons released   | N                  |

\* Amount Spilled: amount spilled - amount recovered = release amount

~ All volumes are estimations based on responding sanitation district/city field staff observations and calculations. Closures based on initial estimated amount reported by sanitation district/city field staff. Final spill volumes (in parentheses and italicized if different from original reported volumes) are reported to the Regional Water Quality Control Boards by the sanitation district/city.

PPO = Private Property Owner