



COUNTY OF ORANGE

HEALTH CARE AGENCY/ENVIRONMENTAL HEALTH OCEAN AND BAY WATER CLOSURES 2020

	Sewage Spill Number	Date Closed	Date Opened	Number of Days Closed	Beach Mile Days	Ocean, Bay, Harbor Area Closed	Agency/Reason	Amount Spilled*	Storm Caused Spill
1	20-029	6/7/2020	6/10/2020	3	0.36	The ocean water area from Sleepy Hollow Lane to Cleo Street in the City of Laguna Beach.	PPO / Sewage tank pump motor failure	~600 gallons/sewage ~0 gallons recovered ~600 gallons released	No
2	20-030	6/22/20	6/25/20	3	1.62	All of Huntington Harbour	City of Huntington Beach / Break in the force main	~100 gallons/sewage ~0 gallons recovered ~100 gallons released	No

* Amount Spilled: amount spilled - amount recovered = release amount

~ All volumes are estimations based on responding sanitation district/city field staff observations and calculations. Closures based on initial estimated amount reported by sanitation district/city field staff. Final spill volumes (in parentheses and italicized if different from original reported volumes) are reported to the Regional Water Quality Control Boards by the sanitation district/city.

PPO = Private Property Owner