



COUNTY OF ORANGE PUBLIC HEALTH OCEAN AND BAY WATER CLOSURES 2021

	Sewage Spill Number	Date Closed	Date Opened	Number of Days Closed	Beach Mile Days	Ocean, Bay, Harbor Area Closed	Agency/Reason	Amount Spilled*	Storm Caused Spill
1	21-011	3/15/2021	3/18/2021	3	1.5	From Bayside Drive Beach to China Cove, Newport Beach	City of Newport Beach / Operator error during routine maintenance of a sewer main	~1000 gallons/sewage ~0 gallons recovered ~1000 gallons release	N
2	21-055	10/19/2021	10/21/2021	2	0.23	100 yards north to 100 yards south of the Warner Public Docks in Huntington Harbour	City of Huntington Beach / Pumpout failure at public dock	~250 gallons/sewage ~0 gallons recovered ~250 gallons release	N
3	21-068	12/31/2021	12/31/2021**	1	1.00	All of Seal Beach's main beach	Los Angeles County Sanitation District	~6-7 million gallons/sewage ~0 gallons recovered ~6-7 million gallons release	N

* Amount Spilled: amount spilled - amount recovered = release amount

** Spill expanded and continued until 1/3/2022

~ All volumes are estimations based on responding sanitation district/city field staff observations and calculations. Closures based on initial estimated amount reported by sanitation district/city field staff. Final spill volumes (in parentheses and italicized if different from original reported volumes) are reported to the Regional Water Quality Control Boards by the sanitation district/city.

PPO = Private Property Owner